



NOTES:

1. SIGNS SHALL BE PLACED AS REQUIRED UNDER THE PROVISIONS OF PERMIT ISSUED BY FDEP. THE ABOVE SIGNS SHALL BE USED WHEN REQUIRED BY FDEP AND/OR SLWSD.
2. MOUNT SIGN TO STANDARD U-CHANNEL SIGN POST WITH STAINLESS STEEL HARDWARE.
3. SIGN SHALL BE .080 GAUGE ALUMINIUM WITH VINYL COATING.
4. THE LETTERS SHALL BE BLACK AGAINST A WHITE BACKGROUND, OTHER COLORS MAY BE USED WITH PRIOR APPROVAL OF SLWSD.



**MINIMUM CONSTRUCTION STANDARDS FOR
ST. LUCIE WEST SERVICES DISTRICT**
450 SW UTILITY DRIVE,
PORT SAINT LUCIE, FL 34986
PHONE: (772) 340-0220

**RECLAIMED WATER
SITE SIGNAGE**

DETAIL: SLWG-15
DATE: 03/2020
SCALE: N.T.S.
SHEET: 1 OF 1